

Short Form Classification Report No. 19808F

PRODUCT

RockFace A2 FR

SPONSOR

RADMAT BUILDING PRODUCTS LTD

PRODUCT DETAILS

Fibre cement board (top layer)

- Nominal thickness and density: 6,0 mm, 1320 kg/m³
- No use of fire retardants
- Colour: White-grey

Glue

- Applied amount: 124 g/m² (dry)
- No use of fire retardants

Mineral wool thermal insulation (core material)

- Nominal thickness and density: 50 mm, 110 kg/m³
- No use of fire retardants
- Colour: Yellow-green

FIELD OF APPLICATION

- Substrate: Euro class A2-s1,d0 or better, excluding paper faced gypsum plaster boards, with a minimal thickness of 9 mm and a minimal density of 652,5 kg/m³
- Without air gap
- Fixing: Mechanically fixed using screws
- With or without horizontal and/or vertical butt joints
- Fire exposed side: Fibre cement board.

CLASSIFICATION

A2-s1,d0

STANDARDS

Test standard: EN ISO 1716:2010 & EN 13823:2010+A1:2014

Classification standard: EN 13501-1:2018

SIGNED

APPROVED

For and on behalf of WFRGENT nv

This short form classification report has been drafted according to EGOLF agreement EGA 08rev2:2013 "Application note: clause 5.10 [5.10/1] – Types of test reports used in fire testing". Whilst the test data and classification provided within this short form report was obtained in a test conducted fully in accordance with the standards EN ISO 1716:2010, EN 13823:2010+A1:2014 & EN 13501-1:2018, the presentation of the results in this short form report may not satisfy the requirements of those standards and EN ISO/IEC 17025:2005/AC:2006. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted.

The full classification report No. **19808E** is available at **RADMAT BUILDING PRODUCTS LTD**.

This document is the original version of this report and is written in English. This document may be used only literally and completely for publications. For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.